

PROJECT MANUAL GUIDE SPECIFICATIONS FOR PFANNENBERG MODEL DS 5 SOUNDER

PART 1 – GENERAL

1.1 SUMMARY

A. Visual and audible signaling devices for alarm, warning, and indication are used to promote safety to personnel, create efficiency in movement of people and materials, and report operating status of machinery and processes.

1.2 SECTION INCLUDES

A. Horns, Strobes, Sounders, Flashing Sounders, Signal Towers, LED Beacons, Traffic Lights, Buzzers, and Loudspeakers as scheduled in this section and as indicated on the drawings.

1.3 SUBMITTALS

- A. Product Data: Submit the following manufacturer's documentation for each product specified.
1. Catalog specifications and outline drawings.
 2. Installation and operating instructions.
 3. Certifications to substantiate necessary agency approvals.
- B. Manufacturer Warranty
1. Manufacturer's warranty for Strobes, LED Beacons, Sounders, and Flashing Sounders. Manufacturer's standard 10-year warranty for PYRA Series Strobe Lights, PATROL Series Sounders, PATROL Series Flashing Sounders, DS Series Sounders, Quadro Series Strobe Lights, Quadro Series LED Beacons, and Quadro Series Traffic Lights.

PART 2 – PRODUCTS

2.1 MANUFACTURERS

- A. Basis of Design and Support: To ensure uniformity of operation, standardization of signal types, quality of construction, standard 10-year warranty term, and worldwide localized support, specifications are solely based, wherever practical, on the products of Pfannenber Inc. www.pfannenbergsa.com.
- B. Substitution: Products of a similar nature from other manufacturers may be considered only when performance capabilities, mounting and installation capabilities, environmental use and survivability ratings, operational certifications, and 10-year warranty terms are fully met or exceeded.

2.2 PERFORMANCE / DESIGN CRITERIA

A. Audible Alarm. Model DS 5 Sounder – 105 dB(A) electronic tone generator, horn, siren. As part of the DS series of sounders, this unit is capable of generating multiple tones from an extensive tone menu in order to generate up to four different audible alarm signals based on circumstance or event.

Pfannenber Inc.



The unit has been designed for durability. The die-cast aluminum housing stands up to accidental impacts and the high IP rating permits use in harsh or outdoor environments. The unit takes advantage of sound capsule technology to generate a wider tonal frequency envelope and achieve sound penetration through walls and obstacles, which delivers superior signaling capability when compared to other tone generation methods (such as piezoelectric transducers or vibrating horns).

1. Nominal Output Sound Pressure Level (at 1 meter): 105 dB(A).
2. Operating Voltage Range (pick one): 19 to 29 VDC; 95 to 127 VAC, 195 to 253 VAC.
3. Number of Capable Tones: 31.
4. Operating Temperature Range: -40 to +131 °F (-40 to +55 °C).
5. Dimensions: 5.2 inch (134 mm) h x 5.2 inch (134 mm) w x 5.6 inch (143 mm) d.
6. Housing Material: Die-cast aluminum GD-Al Si12 Cu.
7. Ingress Protection: IP 66, IP 67.
8. Agency Approvals Included: VdS; EN 54-3
9. Warranty Period: 10 years.
10. Optional Features and Accessories (include only if desired)
 - a. Agency Approvals (optional – pick desired only): UL; GL; GOST
 - b. Number of Tone Stages (different tones capable by external control): 4.
 - c. Adjustable volume control.
 - d. SIL conforming – suitable for SIL 1 or SIL 2 installations.

2.3 AUDIBLE ALARMS SCHEDULE

- A. Pfannenberg Model DS 5 Sounder

PART 3 – EXECUTION

3.1 INSTALLATION

- A. Install products in strict compliance with manufacturer’s written instructions and recommendations.

END OF SECTION

Pfannenberg Inc.

Subsidiary of the Pfannenberg Group
68 Ward Road --- Lancaster, NY 14086 --- Phone: 716-685-6866 --- Fax: 716-681-1521
Internet: <http://www.pfannenbergusa.com>

CSI Master Format Sections for which this product may be applicable include the following:

- 25 35 00 Integrated Automation Instrumentation and Terminal Devices for HVAC
 - 25 35 13 Integrated Automation Actuators and Operators
 - 25 35 16 Integrated Automation Sensors and Transmitters
- 25 38 00 Integrated Automation Instrumentation and Terminal Devices for Electronic Safety and Security Systems
- 25 58 00 Integrated Automation Control of Electronic Safety and Security Systems
- 26 06 00 Schedules for Electrical
 - 26 06 20.13 Electrical Switchboard Schedule
 - 26 06 20.16 Electrical Panelboard Schedule
 - 26 06 20.19 Electrical Motor-Control Center Schedule
- 26 24 00 Switchboards and Panelboards
 - 26 24 13 Switchboards
 - 26 24 16 Panelboards
 - 26 24 19 Motor-Control Centers
- 26 27 00 Low-Voltage Distribution Equipment
 - 26 27 16 Electrical Cabinets and Enclosures
 - 26 27 73 Door Chimes
- 26 29 00 Low-Voltage Controllers
 - 26 29 13 Enclosed Controllers
 - 26 29 13.13 Across-the-Line Motor Controllers
 - 26 29 13.16 Reduced-Voltage Motor Controllers
 - 26 29 23 Variable-Frequency Motor Controllers
 - 26 29 33 Controllers for Fire Pump Drivers
 - 26 29 33.13 Full-Service Controllers for Fire Pump Electric-Motor Drivers
 - 26 29 33.16 Limited-Service Controllers for Fire Pump Electric-Motor Drivers
 - 26 29 33.19 Controllers for Fire Pump Diesel Engine Drivers
- 26 55 00 Special Purpose Lighting
 - 26 55 33 Hazard Warning Lighting
 - 26 55 36 Obstruction Lighting
 - 26 55 53 Security Lighting
- 28 06 00 Schedules for Electronic Safety and Security
 - 28 06 30 Schedules for Electronic Detection and Alarm
- 28 26 00 Electronic Personal Protection Systems
 - 28 26 16 Electronic Personal Safety Alarm Annunciation and Control Systems
- 28 30 00 Electronic Detection and Alarm
- 28 31 00 Fire Detection and Alarm
 - 28 31 63.13 Fire Alarm Horns and Strobes
- 28 32 00 Radiation Detection and Alarm
 - 28 32 23 Radiation Detection and Alarm Integrated Audio Evacuation Systems
- 28 33 00 Gas Detection and Alarm
 - 28 33 23 Gas Detection and Alarm Integrated Audio Evacuation Systems
- 28 34 00 Fuel-Oil Detection and Alarm
 - 28 34 23 Fuel-Oil Detection and Alarm Integrated Audio Evacuation Systems
- 28 35 00 Refrigerant Detection and Alarm
 - 28 35 23 Refrigerant Detection and Alarm Integrated Audio Evacuation Systems
- 28 36 00 Water Detection and Alarm
 - 28 36 43 Building Envelope Water Detection and Alarm
 - 28 39 00 Mass Notification Systems

Pfannenber Inc.

Subsidiary of the Pfannenber Group
68 Ward Road --- Lancaster, NY 14086 --- Phone: 716-685-6866 --- Fax: 716-681-1521
Internet: <http://www.pfannenberusa.com>